Weather constraints guide energy storage and heat pump opportunities

Jacqueline A. Dowling

Postdoctoral Energy Fellow Stanford University

Past: Caltech PhD on


Long-Duration Energy Storage

Future: Assistant Prof at University of Iowa in Civil & Environmental Engineering





Solving the Clean Energy Challenge



Blackouts are deadly and electricity reliability is key




Hundreds died during the Texas winter storm power crisis in Feb 2021.



How do we plan electricity systems that dependably meet demand today?

Backup reserves of **dispatchable** fossil or **firm** nuclear generation.

By midcentury, many states and territories aim to dramatically increase wind and solar capacities.




Within 100% carbon-free mandates, many states have wind and solar capacity requirements.




Transition from dispatchable to variable electricity


Load-following electricity is a difficult-to-decarbonize sector



Wind and solar are variable and unreliable



Wind and solar resources vary over daily, seasonal, and interangular annual timescales



Reliability requirement for resource adequacy is that lost load shall not exceed "one hour in a decade"

North American Electric Reliability Corporation

Wind and solar constraints guide energy storage opportunities

Wind and solar constraints

Energy storage opportunity *

Extreme weather years

Ruggles, Virgüez, ..., Dowling et al., APEN, **2024**. Multi-year & seasonal storage functional roles

Dowling et al., Joule, 2020.

Droughts and seasonal lulls

Rinaldi, Dowling et al., ES&T, 2021.



Large volumes of low-cost energy storage

Li*, Virgüez*, Dowling* et al., ES&T, 2024.

Curtailed (wasted) electricity

Ruggles, Dowling et al., APEN, 2024.




Low-efficiency energy storage

Dowling et al., EREN, 2024.


Dowling et al., ACS Appl Eng Mat., 2024.

Wind and solar constraints guide energy storage opportunities




U.S. aggregated data with perfect transmission

Wind and solar constraints guide energy storage opportunities



Various technology options may provide load-following electricity


Clean firm power

















Sector coupling




Long-duration energy storage











Dowling et al., Role of Long-Duration Energy Storage in 10 Variable Renewable Electricity Systems. Joule, 2020.


Inputs:

- Current technology metrics and costs
- Historic wind, solar and demand data

Least-cost optimization:

- Constrains demand to be 100% satisfied at all hours only by wind, solar, and storage
- Objective function minimizes overall system cost
- Solve for capacity and hourly dispatch of each technology with perfect foresight


Primary Tool: Macro-Energy Model












Future work: Multi-nodal PyPSA-USA



For example: What is the tradeoff between spatial and temporal resolution in capturing rare weather events like wind droughts?



Macro Electricity Model (MEM)

Constraints

Capacity:

$$0 \leqslant C^{g,v,s}$$
 $\forall g,v,s.$

Dispatch:

$$\begin{array}{ll} 0 \leqslant D_t^g \leqslant C^g f_t^g & \forall g, t. \\ 0 \leqslant D_t^{\nu} \leqslant C^{\nu} & \forall \nu, t. \\ 0 \leqslant D_t^{\text{to} \, s} \leqslant \frac{C^s}{\tau^s} & s = \text{battery}, \forall t. \\ 0 \leqslant D_t^{\text{from} \, s} \leqslant \frac{C^s}{\tau^s} & s = \text{battery}, \forall t. \\ 0 \leqslant S_t^s \leqslant C^s & \forall s, t. \\ 0 \leqslant D_t^{\text{from} \, s} \leqslant S_t^s \left(1 - \delta^s\right) & \forall s, t. \end{array}$$

Storage energy balance:

$$S_{1} = (1 - \delta^{s}) S_{T} \Delta t + \eta^{s} D_{T}^{\text{to } s} \Delta t - D_{T}^{\text{from } s} \Delta t \qquad \forall s.$$

$$S_{t+1} = (1 - \delta^{s}) S_{t} \Delta t + \eta^{s} D_{t}^{\text{to } s} \Delta t - D_{t}^{\text{from } s} \Delta t \qquad \forall s, t \in 1, \dots, (T-1).$$

System energy balance:

$$\sum_{g} D_t^g \Delta t + D_t^{\text{from } s} \Delta t = M_t + D_t^{\text{to } s} \Delta t \qquad \forall g, t.$$

Electricity sources = Electricity sinks

Dispatch of generation + Storage discharge = Demand + Storage charge

Macro Electricity Model (MEM)

Fixed costs for capacity



Variable costs for dispatch

Objective function

minimize (system cost)

system cost =

$$\sum_{g} c_{\text{fixed}}^{g} C^{g} + \sum_{g} \left(\frac{\sum_{t} c_{\text{var}}^{g} D_{t}^{g}}{T} \right) + \sum_{v} c_{\text{fixed}}^{v} C^{v} +$$

$$\sum_{s} c_{\text{fixed}}^{s} C^{s} + \frac{\sum_{t} c_{\text{var}}^{\text{to } s} D_{t}^{s}}{T} + \frac{\sum_{t} c_{\text{var}}^{\text{from } s} D_{t}^{s}}{T}$$

Minimize system cost:

System cost = Fixed cost * (capacity) + variable cost * (dispatch)

Wind, solar, and storage have **fixed costs**, but **zero variable costs**.

Natural gas has fixed costs (power plant) and variable costs (fuel).



Capacity cost (CapEx) and efficiency define energy storage in the model

Table 2. Base case costs and efficiencies. Assumptions from Hunter *et al* [7] unless otherwise noted.

	Power-to-H ₂	H ₂ storage	H ₂ -to-Power	Battery storage		Wind	Solar
Technology description	PEM electrolysis	Under-ground salt cavern	Stationary PEM fuel cell	Li-ion battery with coupled energy and power and a 4-hour charging time		Wind turbines, onshore	Solar PV, single-axis tracking
Technology type	Conversion	Storage	Conversion	Storage	Conversion	Generation	Generation
Capacity (fixed) cost type	Power capacity (\$ kW ⁻¹)	Energy capacity (\$ kWh ⁻¹)	Power capacity (\$ kW ⁻¹)	Energy capacity (\$ kWh ⁻¹)	Power capacity (\$ kW ⁻¹)	Power capacity (\$ kW ⁻¹)	Power capacity (\$ kW ⁻¹)
Capacity (fixed)	1706	2.0	1415	326	251	1436	1391
Project life (years)	30	30	30	30	30	30	30
Discount rate	0.07	0.07	0.07	0.07	0.07	0.07	0.07
Capital recovery factor (% y ⁻¹)	8.06%	8.06%	8.06%	8.06%	8.06%	8.06%	8.06%
Fixed O&M cost (\$ kW-y ⁻¹ , \$ kWh-y ⁻¹)	13	0.03	13	27	29	43	23
Efficiency	50%	, n—	70%	_		_	_
	36% round-trip efficiency			86% round-trip efficiency		_	_
Loss rate		$0.01\% \text{ y}^{-1}$ $(1.14 \times 10^{-8} \text{ fraction h}^{-1})$		$12.1\% \text{ y}^{-1} (1.38 \times 10^{-5} \text{ fraction h}^{-1})$		_	_
		,	Annualized capi	al costs paid hou	rly		
Fixed cost	0.017 \$ kW ⁻¹ h ⁻¹	0.00002 \$ kWh ⁻¹ h ⁻¹	0.001 \$ kW ⁻¹ h ⁻¹	0.004 \$ kWh ⁻¹ h ⁻¹		0.018 \$ kW ⁻¹ h ⁻¹	0.015 \$ kW ⁻¹ h ⁻
Variable cost	0.000 \$ kW ⁻¹ h ⁻¹	0.000 \$ kWh ⁻¹ h ⁻¹	0.000 \$ kW ⁻¹ h ⁻¹	0.000 \$ kWh ⁻¹ h ⁻¹		0.000 \$ kW ⁻¹ h ⁻¹	0.000 \$ kW ⁻¹ h ⁻

Geologic hydrogen storage is an example long-duration energy storage technology





Energy Storage

Power Conversion

Battery

Low cost!
Charging



Low cost!

Discharging



Demand

86% efficient



Hydrogen

High cost

Charging

Electrolyzer



Low cost!

Geologic H₂ Storage



High cost

Discharging

Fuel cell






Demand

36% efficient

Geologic hydrogen storage is an example long-duration energy storage technology



 Geologic hydrogen storage has the lowest energycapacity cost.

Outline of Results

Long-Duration Energy Storage

- Geologic Hydrogen Storage
- Energy Storage Portfolios
- Competition with Natural Gas


At current technology costs, would long-duration energy storage reduce the cost of reliable wind-solar-battery systems?

Priors before doing this study

- We did not expect hydrogen energy storage to compete at current costs due to high charge/discharge costs and low efficiencies.
- Standard energy models typically used 1
 year of weather data and didn't capture
 seasonal or interannual variability
- California Energy Commission (CEC) definition of long-duration energy storage: > 10 hours


Long-duration storage fills seasonal storage needs at current technology costs

Macro-energy model least-cost optimization results:




 Low-cost energy storage, such as geologic hydrogen, can meet demand during summertime lulls in wind power.


Seasonal and daily storage functional roles



Long-term weather datasets, typically not used by utilities and regulators, capture the role and value of long-duration storage




Multi-year hydrogen energy storage is cost-effective




23

Add hydrogen energy storage at current technology costs:



Addition of hydrogen reduces costs in all cases considered



Key research advance

 At current technology costs, long-duration energy storage reduces the cost of reliable windsolar-battery systems by filling seasonal and multi-year storage functional roles.

Wind and solar constraints guide energy storage opportunities.

Data integration methods advance:

Used multi-decadal weather data Modeled an emerging technology








Outline

Long-Duration Energy Storage

- Geologic Hydrogen Storage
- Energy Storage Portfolios
- Competition with Natural Gas

What is the value of including long-duration storage compared to other energy storage options?


Energy Storage Options




Geologic hydrogen storage and metal-air batteries were the most cost-effective energy storage technologies modeled due to their *low energy capacity costs*.

- Hydrogen: ~2 \$/kWh energy-capacity cost
- Metal-air batteries: ~5 \$/kWh energy-capacity cost (20 \$/kWh total cost with a fixed 100-h duration)


System costs of different energy storage portfolios (continental U.S.)




1. Deploying <u>underground hydrogen storage</u> or <u>metal-air batteries</u> led to the lowest total system costs




Long-duration storage **reduces wind-capacity overbuild** by meeting demand during summertime lulls in wind power.



1. Deploying <u>underground hydrogen storage</u> or <u>metal-air batteries</u> led to the lowest total system costs




Metal-air batteries and geologic hydrogen storage have the **lowest** energy-capacity costs considered.




Energy-Capacity Total Overnight Cost (\$/kWh)

2. Long-duration storage may also cost-effectively provide short-term storage




Deploying Li-ion batteries with a longerduration storage technology does not substantially lower total system costs

2. Long-duration storage may also cost-effectively provide short-term storage



2. Long-duration storage may also cost-effectively provide short-term storage




Outline

Long-Duration Energy Storage


- Geologic Hydrogen Storage
- Energy Storage Portfolios
- Competition with Natural Gas

At what degree of decarbonization would hydrogen storage compete with natural gas?

At what degree of decarbonization do hydrogen storage technologies compete with natural gas?



Geologic hydrogen storage can reduce electricity costs in wind and solar systems with natural gas restricted to 17% of demand.




Range of technology options


Lower cost options:

Base case:

Higher cost options:



Geologic hydrogen storage is much more competitive with natural gas than aboveground tank storage



39


Outline


What capacity limits are there to geologic hydrogen energy storage?

Constraints and Innovation

- Underground Storage Constraints
- High- and Low-Value Innovation
- Shift in Materials Chemistry Focus


How much hydrogen energy storage might we want?







~175 TWh in least-cost reliable wind-solar-H₂-battery system in the U.S. However, system costs are quite *insensitive* to that value if we constrain it.

Even with tight capacity limits in salt caverns, H₂ storage still reduces system costs






System cost impact of salt cavern volume restriction:



Salt cavern + Depleted reservoirs 327 TWh (SHASTA)

Ample capacity in *existing* natural gas infrastructure



How much storage is optimal?


Approx. Total needed: ~175 TWh (Dowling et al.) of hydrogen working gas

How much storage is available in active natural gas storage facilities?

Salt Caverns: 36 TWh
Depleted reservoirs: 291 TWh
Total available: 327 TWh (SHASTA)
of hydrogen working gas

Repurposing about <u>half</u> the volume available in active U.S. natural gas storage facilities for pure hydrogen would provide *national-scale seasonal* energy storage in a 100% reliable wind-solar-hydrogen electricity system.

Vast potential for <u>new</u> geologic hydrogen energy storage



Salt Caverns

Pro: Commercially proven for H₂, Con: Constrained Capacity

Depleted Reservoirs

Pro: Abundant capacity
Con: Emerging technology for H₂


Outline

Which hydrogen energy storage innovations are most valuable for reducing reliable wind and solar system costs?


Constraints and Innovation

- Underground Storage Constraints
- High- and Low-Value Innovation
- Shift in Materials Chemistry Focus

Which innovation is more valuable for hydrogen storage systems? Capital cost or efficiency improvements?




Capital cost improvements were more valuable than efficiency improvements




High-value innovation: Improve fuel cell capital cost or salt cavern cost Low-value innovation: Improve electrolyzer efficiency


Starting from base case:
PEM | Salt | PEM



For any long-duration energy storage technology... High-value innovation:

Improve energy storage capital cost or discharger capital cost






Dirt-cheap energy storage!




- Thermal energy storage in dirt uses soil or rock to store energy at low energy capacity costs (\$0.01/kWh).
- Grid electricity heats water in pipes, which transfer heat to the surrounding dirt.
- This stored thermal energy can then be used to repower steam turbogenerators at decommissioned coal power plants. Repurposing means a very low discharger cost of (\$250 /kW).





Thermal energy storage in dirt fills a seasonal storage role without an emissions constraint!



- In electricity systems reliant on wind, solar, and natural gas generation, thermal storage in dirt could play a key role in addressing seasonal electricity demand challenges, increasingly so with larger shares of wind and solar generation.
- Natural gas and thermal energy stored in dirt provide electricity primarily to meet seasonal residual demand challenges posed by wind lulls and concurrent demand peaks.

Outline

How can we develop electrolyzer catalysts specifically for energy storage applications in wind and solar systems?


Constraints and Innovation

- Underground Storage Constraints
- High- and Low-Value Innovation
- Shift in Materials Chemistry Focus


Low-value innovation: Improve electrolyzer efficiency

Can we take advantage of this?

Starting from base case:
PEM | Salt | PEM




Commercial proton-exchange membrane (PEM) electrolyzers depend on precious metal catalysts




Water splitting: $H_2O \rightarrow H_2 + \frac{1}{2}O_2$










Iridium demand and volatile prices pose a risk to scale-up of PEM electrolyzers

Explicit targeting of a lower-efficiency, but more earth-abundant catalyst





ACS Publications




Represents a shift in materials chemistry focus guided by system-level analysis.


Where would this new catalyst be on the map?

Potentially similar total system cost, but not as dependent on critical materials.

Potential improvement on **energy security** objectives.




Wind and solar constraints guide energy storage opportunities



Conclusions:

Long-Duration Energy Storage Opportunities



Dowling et al., Joule, 2020.

Dowling et al., EREN, 2024.

Dowling et al., ACS Appl Eng Mat., 2024.

Li*, Virgüez*, Dowling* et al., ES&T. 2024.

Long-Duration Energy Storage

Geologic Hydrogen Storage

Long-duration energy storage reduces the cost of reliable windsolar-battery systems by **filling seasonal and multi-year storage functional roles**.

Energy Storage Portfolios


Long-duration energy storage **may also satisfy short-term storage needs**.

Competition with Natural Gas

Geologic hydrogen storage competes with natural gas in deep decarbonization scenarios due to its **low energy capacity costs**.

Conclusions:

Long-Duration Energy Storage Opportunities



Dowling et al., Joule, 2020.

Dowling et al., EREN, 2024.

Dowling et al., ACS Appl Eng Mat., 2024.

Li*, Virgüez*, Dowling* et al., ES&T. 2024.

Constraints and Innovation

Underground Storage Constraints

Half of the active natural gas storage sites in the U.S. could beneficially be repurposed for national-scale seasonal energy storage.

High- and Low-Value Innovation

Due to curtailment, innovation in hydrogen storage system capital cost is **more valuable than efficiency innovation** for energy storage applications in wind and solar-based electricity systems.

Shift in Materials Chemistry Focus

Explicitly targeted a **lower-efficiency but more earth-abundant** catalyst guided by system-level analysis.

Interdisciplinary Approach to Energy Storage PhD

1. Analyze resource constraints



Climate Science

Macroenergy

systems

Wind and solar constraints


2. Guide technology innovation



Electrochemistry

Energy storage innovation

3. Target decarbonization solutions



A Global fossil fuel & industry emissions, 2014 (33.9 Gt CO₂)



Load-following electricity

Interdisciplinary Approach to Clean Heat Postdoc

1. Analyze resource constraints



Earth System Science

Temperature constraints

Steve Davis

2. Guide technology innovation



Energy Science & Engineering


Data

analysis

Heat pump innovation

Adam Brandt Inês Azevedo

3. Target decarbonization solutions




A Global fossil fuel & industry emissions, 2014 (33.9 Gt CO₂)



Net-zero emissions heat

Net-zero emissions heat



What does it cost to decarbonize U.S. heat demand in buildings and industry?



Buildings

Industry






Dimitri Saad

Specific heat demands may be difficult-to-decarbonize


Fraction of space heating energy from fossil fuels



Add heat pumps, but no new electricity distribution



Fraction of space heating energy from fossil fuels





Electricity distribution upgrades pose challenges for decarbonizing building spaceheating in cold climates via **heat pumps**.

Knowledge Gap: No cost estimation.

Dataset: Census-tract level, hourly temperature-derived building heat demand over 10 years. (Waite & Modi)

Key Questions

Net-zero emission heat


What does it <u>cost</u> to decarbonize heat U.S. heat demand in buildings and industry?

- What are the key cost drivers?
- Are there key thresholds in cumulative abatement costs?
- What are the key sensitivities?

Data analysis of difficult-to-decarbonize heat demands to guide technology innovation priorities

Primary Tool: Abatement Cost Equation

Considers a technology replacement cost and emissions change



$$Abatement \ Cost = \frac{Cost_{new} - Cost_{old}}{Emissions_{old} - Emissions_{new}}$$


Negative (-) abatement costs

identify locations where heat pump electrification saves money.

Large positive (+) abatement costs

identify difficult-todecarbonize heat demands guiding innovation priorities.

Cost and Emissions Assumptions



Natural Gas Propane Fuel oil Coal

Census tract





Heat pump


Distribution upgrade

Clean **Electricity**



Fuel oil, kerosene 0.082 tCO2/MMBtu Coal 0.106 tCO2/MMBtu

Temperature data constrains heat pump efficiency




In very cold weather below -27 °C, heat pump efficiency = 1.

Target indoor temperature is 18 °C, or 65 °F.


- We assume performance of the top 90% best heat pumps currently commercially available (Green line).
- Linear approximation:

Heat Pump Efficiency = 0.111 * Temperature + 4.0

Average heat pump efficiency weighted by new electricity load is 4.




Heat pump electrification reduces total energy demand for heat



New Heat Electrification
$$[kWh_e] = \frac{Fossil\ Heat\ Demand\ [kWh_{th}]}{Heat\ Pump\ Efficiency\ [\frac{kWh_{th}}{kWh_e}]}$$


- Average heat pump efficiency weighted by new electricity load is 4.
- Total energy demand for heat is lower because heat pumps are more efficient than fossil fuels.

However, heat pump electrification can increase peak load



- Heat electrification increases peak load massively in an example CO census tract in 2017.
- Hourly peak
 difference due to
 heat electrification
 determines
 distribution upgrade
 need.

Distribution upgrade prices are expensive and have been rising





Distribution upgrade prices are rising faster than inflation. These prices include poles, wires, undergrounding, & transformers. To estimate utility-specific distribution upgrade prices (\$/kW):


 Match year-over-year CapEx additions from FERC Form 1 (\$) with peak demand from EIA-861 as a proxy for distribution capacity (kW).

Knowledge Gap: Heat pump electrification studies rarely include distribution upgrade costs, and potential distribution investment needs haven't yet been estimated nationwide at the census tract level.

Initial Results: Electrification of Fossil Heat in Buildings









Abatement
$$Cost = \frac{Cost_{clean} - Cost_{fossil}}{Avoided \ Emissions_{fossil}}$$

- Many census tracts across the U.S. can electrify building heating at a profit (blue tracts) or costneutrally (white tracts)!
- Carbon abatement costs for building heat electrification are highest (red tracts) in the Mountain West division, where distribution investments are greatest.
- Abatement costs, weighted by emissions avoided, average \$230/tCO₂ at the census tract level, just above the social cost of carbon (\$212/tCO₂), but range from -\$286/tCO₂ to over \$3500/tCO₂.

Distribution Investments: Normalizing by emissions changes the picture




Drivers: Electrification of Fossil Heat in Buildings




Distribution investment per unit of emissions avoided is the primary driver for high abatement cost states.

$$Abatement\ Cost = \frac{Cost_{clean} - Cost_{fossil}}{Avoided\ Emissions_{fossil}}$$


Drivers: Electrification of Fossil Heat in Buildings





 Counties with low abatement costs also tend to have low spark spreads.

Emissions-Weighted Abatement Costs



Profitable to abate


Heat pump electrification in AZ and WA would save money!

• Emissions-weighted average abatement cost by census tract is \$230/tCO₂.

$$Abatement\ Cost = \frac{Cost_{clean} - Cost_{fossil}}{Avoided\ Emissions_{fossil}}$$

- Although MT, CO, WY have very high abatement costs, those states doesn't represent very many emissions.
- Targeting NY, PA, CA would avoid more emissions at lower cost.

Thresholds in Cumulative Emissions Avoided



• For only 50% of the cost avoid 60% of the emissions! Buy now! ©

Absolute values for a sense of scale

Success scenario: Abatement costs guide actions

Success scenario:

Abatement costs guide actions



Negative (-) abatement costs

identify locations where heat pump electrification saves money.



Where should heat pumps or other clean heat technology be deployed now?

Deploy clean heat technology



Industrial facilities & census tracts



Large positive (+) abatement costs identify difficult-to-decarbonize heat demands guiding innovation priorities.



What clean heat tech innovations could decarbonize which heat demands?

*Future work: sensitivity studies

Guide clean heat tech innovation



CapEx, OpEx, efficiency

Weather data guides technology opportunities for decarbonization solutions







Wind and solar data to guide *energy storage* opportunities












Loadfollowing electricity





Temperature data to guide heat pump opportunities



Heat pump



Net-zero emissions heat

Solving the Clean Energy Challenge



Reliable energy transitions given wind and solar droughts

Wind, solar, & hydro droughts

Critical materials

Water for Energy constraints

Subsurface constraints



Macro-energy systems to guide clean-tech innovation

Energy storage for load-following electricity


Clean heat for residential & industrial demand



Repurpose fossil infrastructure for decarbonization solutions

E.g. Coal to thermal energy storage. Gas to hydrogen storage. Coordinate fossil phase-down and infrastructure transitions

Thank you for listening!



Clean Energy Systems Research

Jacqueline A. Dowling

Stanford | ENERGY Postdoctoral Fellowship

MERGING TALENTS
EMERGING IDEAS






Wind and solar constraints guide energy storage opportunities

Job market prep that helped me:

- Write papers you are excited about and present them at conferences!
- Coordinated with friends to gather job ads and deadlines in a google spreadsheet.
- Read example successful faculty application packages from friends.
- Went to workshops. Most useful tip for me: Organize your past and future research program into verb-driven thrusts. This made everything so much more concise.
















Super helpful book that levels the playing field. I found it especially helpful for interview prep.



